

Minimum Technical Specifications (Split AC) Title1		
1	Make	Blue star/Carrier/Voltas/Hittachi make
2	Nominal capacity (Tr)	1.5 Tr
3	Star Rating	5 star or Higher
4	Cooling Capacity (watt)	5000 ± 5 %
5	Cooling Capacity (Min~ Max) BTU / Hr	17060(6950 ~ 18244)
6	Cooling Power Input (50% Load) Watt	447
7	ISEER	5.02 or better
8	Electricity Consumption in 1600 Hr (Unit/year)	770.98 unit per year or less
9	Air flow volume (wet CFM) (High/Medium/Low)	580/461/307 ± 5 %
10	Power Supply	230 V minimum 50 hz,Single Phase
11	Noise Level indoor (db (a)) High/Medium/Low	50 db max on high Speed 50 db ± 2 %
12	Ambient Temperature Range (Cooling)' C	21°C To 54°C
13	Compressor Type	inverter Rotary
14	Eco Friendly Refrigerent	R-32
15	Compressor warranty	10 Years
16	Product type	Inverter split AC
17	Condenser Type	100 % Copper
18	Durability	Anticorrosive condenser fins Blue , Evaporator fins-Hydrophilic Blue
19	Remote	LCD Display Remote
20	Mode	5 in 1 convertible mode
21	Warranty on Electronic PCB (indoor and Outdoor)	5 years or more
22	Comprehensive warranty	1 years or more
23	Features	(1) Turbo cool mode, (2) 100 % copper, (indoor and Outdoor) (3) Acoustic Jacket around Compressor, (4) 4 way swing (5) DigiQ Penta Sensor (6) Specially designed acoustic to eliminate noise and vibration for AC Operation Quieter, (7) Anti corrosive on evaporator coils in the indoor units & on condenser coils in outdoor units to resist corrosion & PCB Metal Encloser , Accostic Compressor Jacket , Electronic Expension Valve (EEV) to enhance durability.

Minimum Technical Specifications (Voltage Stablizer) Title2		
1	Make	Blue Star /V-guard/Capri/Microtek
2	Voltage Range	150 V - 280 V
3	Display	Digital Analog Meter
4	Warranty	3 Years or More
5	Winding	Copper
6	Features	(1)Intelegant Time Delay System (ITDS) (2)Built in Thermal Overload Protection (3)Low and High Voltage Cut off Protection (4) Boosting and Bucking (30 V Boost , 25 V Bucking)

Technical Specifications Title3, Title4, Title5		
	FBR AC Copper piping .	Please note that the specifications of all item under Title3,4 & 5 should be similar to the items supplied with under Title1
	Split AC Cable	
	Split AC Drain Pipe	